

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: LJ43119
Work Order: 10102973_01

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS AR CF	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	0.16	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	0.009	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: **LJ43120**
Work Order: **10102973_02**

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS AR CF F	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	0.001	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: LJ43121
Work Order: 10102973_03

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS KIT KF	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	0.10	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	0.003	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: LJ43122
Work Order: 10102973_04

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS KIT KF F	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	Not detected	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: **LJ43123**
Work Order: **10102973_05**

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS PS CF	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	0.001	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: **LJ43124**
Work Order: **10102973_06**

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS PS CF F	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	Not detected	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: LJ43125
Work Order: 10102973_07

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS YP CF	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	Not detected	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: **LJ43126**
Work Order: **10102973_08**

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS YP CF F	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	Not detected	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: **LJ43127**
Work Order: **10102973_09**

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS TR CF	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	0.26	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	Not detected	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: LJ43128
Work Order: 10102973_10

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS TR CF F	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	Not detected	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: **LJ43129**
Work Order: 10102973_11

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS IR CF2	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	0.07	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	0.002	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: LJ43130
Work Order: 10102973_12

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS IR CF2 F	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	0.06	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	0.001	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: **LJ43131**
Work Order: **10102973_13**

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS IR CF 1	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	Not detected	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	0.001	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Official Laboratory Report

Report To: HOLLY GOHLKE
2100 WEST M 32
GAYLORD MI 49735

Sample ID: LJ43132
Work Order: 10102973_14

System Name/Owner:	FUTURE SCHOLARS/DC500370058	WSSN/Pool ID:	
Collection Address:	330 CROCKER BLVD, MOUNT CLEMENS	Source:	Other
Collected By:	SPODNEY	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	Macomb	Date Collected:	01/28/2021 00:01
Sample Point:	LS IR CF1 F	Date Received:	01/28/2021 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper 250 mL Sample	0.08	mg/L	0.05	01/29/2021	1.3	EPA 200.8	7440-50-8
Lead 250 mL Sample	Not detected	mg/L	0.001	01/29/2021	0.015	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Macomb County Health Dept.
43525 Elizabeth
Mount Clemens, MI 48043
586 469-5236**

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		